

Exova Warringtonfire
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 655 116
F : +44 (0) 1925 655 419
E : warrington@exova.com
W: www.exova.com



Testing. Advising. Assuring.

Title:

The Fire Resistance Performance Of an Insulated, Single-Acting Double-Leaf Doorset When Tested In Accordance With BS 476: Part 22: 1987, Clause 6

WF Report No:

391290 Issue 2



Prepared for:

Braga Spa
Via Ezio Vanoni
Casalmaggiore
Italy

Date:

11th June 2018



Conclusions

Evaluation against objective An insulated single-acting, double-leaf doorset, has been subjected to a fire resistance test in accordance with BS 476: Part 22: 1987, Clause 6.

The evaluation of the doorset against the requirements of BS 476: Part 22: 1987, Clause 6 showed that it satisfied the requirements of the periods stated below:

Test Results:

Integrity 41 minutes

The test was discontinued after a period of 42 minutes.